


Cherry Corp.
Standard MP

Terminates to Wago in control panel
Needs greater than 1k resistor at Wago , hall cant
take more than 24 mA



		Monterey Bay Aquarium Research Institute 7700 Sandhold Road, Moss Landing, CA 95039	
		Title <Title>	
Engineer <Engineer>	Size A	Document Number <Doc>	Rev <Rev>
Layout <Layout>	Date: Thursday, September 13, 2012		
Sheet		1	of 1